

DIAMOND C-20 and C-30 Liquid-Cooled OEM Lasers

Preinstallation Manual

*Preinstallation Manual
DIAMOND C-20 and C-30
Liquid-Cooled OEM Lasers*



COHERENT®

1280 Blue Hills Avenue
Bloomfield, CT 06002

This document is copyrighted with All Rights Reserved. Under copyright laws, this document must not be copied in full or in part, or reproduced by any other media, without the express written permission of Coherent, Inc. (Coherent). Permitted copies must have the same proprietary and copyright notices as were attached to the original. This exception does not permit copies—whether or not sold—to be made for others; however, all the material purchased can be sold, given, or loaned to another person. Under the law, “copying” includes translation into another language.

Coherent and the Coherent Logo are registered trademarks of Coherent, Inc. All other trademarks or registered trademarks are the property of their respective owners.

Patents referenced in this manual are active when the manual is printed. For a list of current patents, see www.coherent.com/company/patents.

Every effort was made to make sure that the data shown in this document is accurate. The information, figures, tables, specifications, part numbers, and schematics contained in this manual are subject to change without notice. Coherent makes no warranty or representation, either expressed or implied, related to this document. In no event will Coherent be liable for any direct, indirect, special, incidental, or consequential damages caused by any defects in its documentation.

Technical Support

In the U.S.:

Should you experience any difficulties with your laser or need any technical information, please go to our web site www.coherent.com. Should you need further assistance, please contact Coherent Technical Support by e-mail customer.support@coherent.com or telephone, 1-800-367-7890 (1-408-764-4557 outside the U.S.). Please be prepared to supply the model and laser head serial number of your laser system also the description of the problem and any attempted corrective steps to the Product Support Engineer responding to your request.

Telephone coverage is available Monday through Friday (except U.S. holidays and company shutdowns). Inquiries received outside of normal office hours will be captured by our automatic answering system and will be quickly returned the next business day.

Outside the U.S.:

If you are located outside the U.S., please visit www.coherent.com for technical assistance, or contact your local Service Representative. Service Representative telephone numbers and addresses can be found on the Coherent web site.

Coherent provides telephone and web-based technical assistance as a service to its customers and assumes no liability for any injury or damage that can occur at the same time with such services. Under no conditions do these support services effect the terms of any warranty agreement between Coherent and the buyer. Operation of any Coherent laser with any of its interlocks defeated is always at the operator's own risk.

TABLE OF CONTENTS

1 Introduction	1
1.1 Signal Words and Symbols in this Manual	1
1.1.1 Signal Words	1
1.1.2 Symbols	2
1.2 Preface	3
1.3 Export Control Laws Compliance	4
1.4 Notice Concerning Regulatory Status of DIAMOND Series Lasers	4
1.5 Notice Concerning Warranty	4
1.6 The Preinstallation Manual	5
1.6.1 Intended Audience	5
1.6.2 Numbering of Sections, Pages and Instructions	5
1.6.3 Cited Standards	6
1.7 Units of Measurements	6
1.8 Feedback Regarding Documentation	7
1.8.1 Feedback Address	7
2 Laser Safety	9
2.1 Hazards	9
2.1.1 Optical Safety	10
2.1.1.1 Recommended Precautions and Guidelines	10
2.1.1.2 Laser Safety Eyewear	11
2.1.1.3 Viewing Distance	12
2.1.2 Electrical Safety	13
2.1.2.1 Recommended Precautions and Guidelines	13
2.2 Safety Features and Compliance with Government Requirements	14
2.2.1 Laser Classification	14
2.2.2 Protective Housing	14
2.2.3 Protective Covers (Safety Interlocks)	15
2.3 Compliance to Standards Relevant to CE Mark	15
2.4 Environmental Compliance	16
2.4.1 Electromagnetic Compatibility	16
2.4.2 RoHS Compliance	16
2.4.3 China RoHS Compliance	16
2.4.4 EU REACH	17
2.4.5 Waste Electrical and Electronic Equipment (WEEE)	18

2.5 Labeling	18
2.6 Sources of Additional Information	22
2.6.1 Laser Safety Standard	22
2.6.2 Publications and Guidelines	22
3 Description and Specifications	23
3.1 Introduction	23
3.2 Purpose of This Manual	23
3.3 Specifications and Input Requirements	24
3.4 Hardware Overview	24
3.4.1 DC Input Power	24
3.5 Cooling Requirements	25
3.5.1 Comparison of Liquid Cooling & Air Cooling (Reference)	25
3.5.2 Liquid-Cooling Option of C-20 and C-30	26
3.6 Laser Head	27
3.7 RF Power Module	27
3.8 Specifications, Configuration, and Facility Requirements	28
4 Utility Requirements and System Installation	29
4.1 Introduction	29
4.2 Unpacking and Inspection	29
4.2.1 Verifying Delivery	29
4.2.2 Protective Shipping Tape	29
4.2.2.1 Tape Removal	30
4.3 Safety Issues in Laser Installation	31
4.4 Mechanical Mounting	32
4.4.1 Mounting Considerations for C-20 and C-30	32
4.5 Liquid Cooling	34
4.5.1 Cooling System Layout	34
4.5.2 Coolant Composition	35
4.5.3 Re-Circulation and Coolant Flow Interlock Switch	36
4.5.4 Signal Interface	36
4.5.5 Thermal Shutdown Circuit	37
4.5.6 DC Power Relay	37
4.5.7 Condensation of Water Vapor	37
4.5.8 Coolant Fittings on Laser System	38
4.5.9 Cooling Capacity	38
4.5.10 Coolant Filtering	39
4.5.11 Coolant Flow Rate and Pressure	39

4.5.12 Pressure Drop	39
4.6 Electrical Power Connection.....	40
4.6.1 DC Power Supply Requirements.....	41
4.6.1.1 DC Power Supply Cabling Requirements	41
4.7 Control Signal Connection	42
4.8 Beam Propagation	44

LIST OF ILLUSTRATIONS

2-1. Nominal Ocular Hazard Distance (NOHD).....	12
2-2. Environment-Friendly Use Period Symbol.....	16
2-3. Manufacture Date	17
2-4. Waste Electrical and Electronic Equipment Label.....	18
2-5. Location of Safety Labels	18
3-1. C-20 and C-30 Liquid-Cooled Laser	23
3-2. Cooling System Diagram.....	26
4-1. Protective Shipping Tape.....	30
4-2. C-20 and C-30 Liquid-Cooled Laser Head Dimensions	33
4-3. Recommended Liquid Cooling System Functional Block Diagram	34
4-4. Water Circuits - Untreated and Treated	36
4-5. C-20 and C-30 Liquid Cooling Connections.....	38
4-6. Electrical Connections to C-20 and C-30.....	40
4-7. Beam Diameter vs. Distance from Laser Head.....	44

LIST OF TABLES

3-1. Comparison: The Benefits of Liquid Cooling vs. Air Cooling Methods	25
3-2. C-20 and C-30 Liquid-Cooled Configuration and Facility Requirements.....	28
4-1. Recommended Coolant for C-20 and C-30 Lasers	35
4-2. Signal Interface Description and Connector Pinout.....	43

1 INTRODUCTION

1.1 Signal Words and Symbols in this Manual

This documentation may contain sections in which particular hazards are defined or special attention is drawn to particular conditions. These sections are indicated with signal words in accordance with ANSI Z-535.6 and safety symbols (pictorial hazard alerts) in accordance with ANSI Z-535.3 and ISO 7010.

1.1.1 Signal Words

Four signal words are used in this documentation: **DANGER**, **WARNING**, **CAUTION** and **NOTICE**.

The signal words **DANGER**, **WARNING** and **CAUTION** designate the degree or level of hazard when there is the risk of injury:

DANGER!

Indicates a hazardous situation that, if not avoided, will result in death or serious injury. This signal word is to be limited to the most extreme situations.

WARNING!

Indicates a hazardous situation that, if not avoided, could result in death or serious injury.

CAUTION!

Indicates a hazardous situation that, if not avoided, could result in minor or moderate injury.

The signal word "**NOTICE**" is used when there is the risk of property damage:

NOTICE

Indicates information considered important, but not hazard- related.

Messages relating to hazards that could result in both personal injury and property damage are considered safety messages and not property damage messages.

1.1.2

Symbols

The signal words **DANGER**, **WARNING**, and **CAUTION** are always emphasized with a safety symbol that indicates a special hazard, regardless of the hazard level:



This symbol is intended to alert the operator to the presence of additional information.



This symbol is intended to alert the operator to the presence of important operating and maintenance instructions.



This symbol is intended to alert the operator to the danger of exposure to hazardous visible and invisible laser radiation.



This symbol is intended to alert the operator to the presence of dangerous voltages within the product enclosure that may be of sufficient magnitude to constitute a risk of electric shock.



This symbol is intended to alert the operator to the danger of Electro-Static Discharge (ESD) susceptibility.



This symbol is intended to alert the operator to the danger of crushing injury.



This symbol is intended to alert the operator to the danger of a lifting hazard.

1.2

Preface

This is the Operator's Manual for the DIAMOND C-20 and C-30 OEM/ Industrial laser manufactured by Coherent. These lasers are OEM systems; they are designed as components which are to be inserted by the original equipment manufacturer (OEM) prior to delivery to the end user. Coherent requires that the user read "Laser Safety" (p. 9), before operating the laser.



NOTICE

Read this manual carefully before operating the laser for the first time. Failure to follow the instructions and safety precautions in this manual can result in serious injury or death. Special attention must be given to the material in "Laser Safety" (p. 9), that describes the safety features built into the laser. Keep this manual with the product and in a safe location for future reference.



DANGER!

Use of controls or adjustments or performance of procedures other than those specified herein may result in hazardous radiation exposure.

1.3 Export Control Laws Compliance

It is the policy of Coherent to comply strictly with U.S. export control laws.

Export and re-export of lasers manufactured by Coherent are subject to U.S. Export Administration Regulations, which are administered by the Commerce Department. In addition, shipments of certain components are regulated by the State Department under the International Traffic in Arms Regulations.

The applicable restrictions vary depending on the specific product involved and its destination. In some cases, U.S. law requires that U.S. Government approval be obtained prior to resale, export or re-export of certain articles. When there is uncertainty about the obligations imposed by U.S. law, clarification must be obtained from Coherent or an appropriate U.S. Government agency.

Products manufactured in the European Union, Singapore, Malaysia, Thailand: These commodities, technology, or software are subject to local export regulations and local laws. Diversion contrary to local law is prohibited. The use, sale, re-export, or re-transfer directly or indirectly in any prohibited activities are strictly prohibited.

1.4 Notice Concerning Regulatory Status of DIAMOND Series Lasers

This laser component does not include all safety features that are required by the United States Food and Drug Administration (FDA), Center for Devices and Radiological Health (CDRH) in laser systems sold to end users. It is sold solely to qualified manufacturers who in their end product, supply interlocks, indicators, and other required safety features, in full compliance with 21 CFR 1040, Subchapter J and/or other applicable national and local regulations.

1.5 Notice Concerning Warranty

Operation or handling of this laser component, inconsistent with this manual, may void the warranty.

1.6 The Preinstallation Manual

This Preinstallation Manual is designed to familiarize the user with the C-20 and C-30 system and its designated use. It contains important information on how to install the laser system safely, properly, and most efficiently. Observing these instructions helps to avoid danger, reduce repair costs, and downtimes and increase the reliability and lifetime of the laser system.

This manual describes the physical hazards related to the laser system, the means of protection against these hazards, and the safety features incorporated in the design of the laser system.

1.6.1 Intended Audience

The Preinstallation Manual is intended for all persons that are to work on or with the laser system.

1.6.2 Numbering of Sections, Pages and Instructions

The sections are numbered continuously. The name of the section appears in the upper outside corner of every odd page. Each section ends with an even page number. Consequently, certain even pages at the ends of sections will be intentionally left blank.

The pages of this manual are numbered continuously by section. The page number appears in the bottom center of every page.

Each step within a procedure is sequentially numbered. Each procedure starts with the step number one.

1.6.3 Cited Standards

Unless otherwise stated, all technical standards cited in this manual relate to the latest version of the standard that is applicable at the date of the publication of this manual.

This information is in compliance with the Performance Standards for Laser Products, ' *United States Code of Federal Regulations*, 21 CFR 1040.10(d). In many cases, the international standards (ISO and IEC standards) have been adopted wholly or in part by national or regional standards authorities and are known locally under the designation assigned by this authority. For instance, the IEC 60825-1 has been adopted by the European Committee for Standardization as the standard EN 60825-1 and, in turn, by various national standards authorities as standards such as DIN EN 60825 (Germany) and BS EN 60825 (United Kingdom). The exact content, number and revision date of the national standard may, however, vary from that of the corresponding international standard. For further information, please contact the publisher of the respective national standard.

1.7 Units of Measurements

In this manual, units of measurement are used according to the metric system (international system of units (SI)), e.g. meter, millimeter, square meter, cubic meter, liter, kilogram, bar, pascal; and imperial system, e.g. tons, pounds, and ounces; gallons and quarts; miles, yards, feet, and inch.

Temperatures are primarily indicated in degrees Celsius (°C) and Fahrenheit (°F).

The water hardness is indicated in parts per million (ppm; American Hardness).

1.8 Feedback Regarding Documentation

If there are any comments regarding the documentation provided, please contact the Coherent Documentation Department.

In any correspondence, please provide the following:

- the document part number, revision, and date of issue,
- the section number, page number and, where applicable, the procedure step number,
- a description of any errors,
- a proposal for improvements.

1.8.1 Feedback Address

E-mail documentation.support@coherent.com

Post Coherent Inc
Documentation and Training Development Department
5100 Patrick Henry Drive, MS-P2-49
Santa Clara, CA. 95054
USA

2

LASER SAFETY



This user information is in compliance with the following standards for Light-Emitting Products IEC 60825-1 / EN 60825-1 “*Safety of laser products - Part 1: Equipment classification and requirements*” 21 CFR Title 21 Chapter 1, Subchapter J, Part 1040 “*Performance standards for light-emitting products*”.

**WARNING!**

LASER RADIATION - AVOID EYE OR SKIN EXPOSURE TO DIRECT OR SCATTERED RADIATION CLASS 4 LASER PRODUCT!

**WARNING!**

Use of controls or adjustments or performance of procedures other than those specified herein may result in hazardous radiation exposure.

This laser safety section must be reviewed thoroughly prior to operating the C-20 and C-30. Safety instructions presented throughout this manual must be followed carefully.

2.1

Hazards

Hazards associated with lasers generally fall into the following categories:

- Biological hazards from exposure to laser radiation that may damage the eyes or skin
- Electrical hazards generated in the laser power supply or associated circuits
- Chemical hazards resulting from contact of the laser beam with volatile or flammable substances, or released as a result of laser material processing

The above list is not intended to be exhaustive. Anyone operating the laser must consider the interaction of the laser system with its specific working environment to identify potential hazards.

2.1.1 Optical Safety

Laser light, because of its optical qualities, poses safety hazards not associated with light from conventional light sources. The safe use of lasers requires all operators, and everyone near the laser system, to be aware of the dangers involved. Users must be familiar with the instrument and the properties of coherent, intense beams of light.

The safety precautions listed below are to be read and observed by anyone working with or near the laser. At all times, ensure that all personnel who operate, maintain or service the laser are protected from accidental or unnecessary exposure to laser radiation exceeding the accessible emission limits defined in the laser safety standards.



WARNING!

Direct eye contact with the output beam from the laser may cause serious eye injury and possible blindness.

The greatest concern when using a laser is eye safety. In addition to the main beam, there are often many smaller beams present at various angles near the laser system. These beams are formed by specular reflections of the main beam at polished surfaces such as lenses or beamsplitters. While weaker than the main beam, such beams may still be sufficiently intense to cause eye damage.

Laser beams are powerful enough to burn skin, clothing, or combustible materials, even at some distance. They can ignite volatile substances such as alcohol, gasoline, ether, and other solvents, and can damage light-sensitive elements in video cameras, photomultipliers, and photodiodes. The user is advised to follow the control measures below.

2.1.1.1 Recommended Precautions and Guidelines

1. Observe all safety precautions in the preinstallation and operator's manuals.
2. Always wear appropriate eyewear for protection against the specific wavelengths and laser energy being generated. See "Laser Safety Eyewear" (p. 11) for additional information.
3. Avoid wearing watches, jewelry, or other objects that may reflect or scatter the laser beam.
4. Stay aware of the laser beam path, particularly when external optics are used to steer the beam.
5. Provide enclosures for beam paths whenever possible.
6. Block the beam before applying tools such as Allen wrenches or ball drivers to external optics.

7. Limit access to the laser to trained and qualified users who are familiar with laser safety practices. When not in use, lasers should be shut down completely and made off-limits to unauthorized personnel.
8. Terminate the laser beam with a light-absorbing material. Laser light can remain collimated over long distances and therefore presents a potential hazard if not confined. It is good practice to operate the laser in an enclosed room.
9. Post laser warning signs in the area of the laser beam to alert those present.
10. Exercise extreme caution when using solvents in the area of the laser.
11. Never look directly into the laser light source or at scattered laser light from any reflective surface, even when wearing laser safety eyewear. Never sight down the beam.
12. Set up the laser so that the beam height is either well below or well above eye level.
13. Avoid direct exposure to the laser light. Laser beams can easily cause flesh burns or ignite clothing.
14. Advise all those working with or near the laser of these precautions.

2.1.1.2

Laser Safety Eyewear

Always wear appropriate laser safety eyewear for protection against the specific wavelengths and laser energy being generated. The appropriate eye protection can be calculated as defined in the “EN 207 Personal eye protection equipment - Filters and eye-protectors against laser radiation (laser eye-protectors)”, in other national or international standards (e.g. ANSI, ACGIH, or OSHA) or as defined in national safety requirements. Anyone working with or near C-20 and C-30 lasers must wear laser safety eyewear with an OD rating 5 eye protection.



CAUTION!

Laser safety eyewear protects the user from accidental exposure to laser radiation by blocking light at the laser wavelengths. However, laser safety eyewear may also prevent the operator from seeing the beam or the beam spot. Exercise extreme caution even while wearing safety glasses.

2.1.1.3 Viewing Distance

The C-20 and C-30 laser produces optical power levels that are dangerous to the eyes and skin if exposed directly or indirectly. These products must be operated only with proper eye and skin protection at all times. Never view directly emitted or scattered radiation with unprotected eyes. When viewing the laser during operation, the operator must maintain the Nominal Ocular Hazard Distance (NOHD) between the laser or scattered radiation and the operator's eyes. Figure 2-1 summarizes the NOHD for the power range of the C-20 and C-30 for direct viewing of the collimated beam along with two other common configurations. The NOHD in Figure 2-1 is based on the Maximum Permissible Exposure (MPE = 0.1 W/cm²) level for each power condition as specified in ANSI Z136.1 and IEC 60825-1.




Figure 2-1. Nominal Ocular Hazard Distance (NOHD) for indicated conditions calculated per IEC 60825-1

2.1.2 Electrical Safety

The C-20 and C-30 uses AC and DC voltages. There are no user serviceable components in the laser and integrated RF power supply. All units are designed to be operated as assembled. Warranty will be voided if the laser head is disassembled.



DANGER!

To avoid potentially fatal electrical shock hazards from electrical equipment, follow all applicable electrical codes such as (in the U.S.) the National Electrical Code.

2.1.2.1 Recommended Precautions and Guidelines

The following precautions must be observed by everyone when working with potentially hazardous electrical circuitry:



DANGER!

When working with electrical power systems, the rules for electrical safety must be strictly followed. Failure to do so could result in the exposure to lethal levels of electricity.

1. Disconnect main power lines before working on any electrical equipment when it is not necessary for the equipment to be operating.
2. Do not short or ground the power supply output. Protection against possible hazards requires proper connection of the ground terminal on the power cable, and an adequate external ground. Check these connections at the time of installation, and periodically thereafter.
3. Never work on electrical equipment unless there is another person nearby who is familiar with the operation and hazards of the equipment, and who is competent to administer first aid.
4. When possible, keep one hand away from the equipment to reduce the danger of current flowing through the body if a live circuit is touched accidentally.
5. Always use approved, insulated tools.

2.2 Safety Features and Compliance with Government Requirements

The following features are incorporated into the instrument to conform to several government requirements:

United States of America:

The applicable United States Government requirements are contained in 21 CFR, Subchapter J, Part 1040 administered by the Center for Devices and Radiological Health (CDRH).

Integrators who incorporate a C-20 and C-30 laser into other products that they introduce into United States commerce are defined in the law as manufacturers who are thus required to manufacture their products to conform to the Federal standard, certify them, and submit product reports to the CDRH.

For jurisdictions outside of the United States, it is the responsibility of the buyer of this laser device to ensure that it meets the local laser safety requirements.

Europe:

The European Community requirements for product safety are specified in the Low Voltage Directive (LVD) (published in 2014/35/EU). The Low Voltage Directive requires that lasers comply with the standard EN 61010-1/IEC 61010-1 "Safety Requirements For Electrical Equipment For Measurement, Control and Laboratory Use" and EN 60825-1/IEC 60825-1 "Safety of Laser Products". Compliance of this laser with the European requirements is certified by the CE mark.

2.2.1 Laser Classification

Governmental standards and requirements specify that the laser must be classified according to the output power or energy and the laser wavelength. The C-20 and C-30 is classified as Class 4 based on 21 CFR, Subchapter J, Part 1040, section 1040.10 (c) and/or IEC/EN 60825-1;2007, Clause 8 and IEC/EN 60825-1:2014, Clause 4. In this manual, the classification will be referred to as Class 4.

2.2.2 Protective Housing

The laser head is enclosed in a protective housing that prevents human access to radiation in excess of the limits of Class radiation as specified in the 21CFR, Part 1040 Section 1040.10 (f)(1) and EN 60825-1/IEC 60825-1 Clause 6.2 except for the output beam, which is Class 4.

2.2.3 Protective Covers (Safety Interlocks)

The RF power module and laser head covers are not interlocked. These covers should never be removed. There are no user-serviceable components inside.



WARNING!

Use of controls or adjustments, or performance of procedures other than those specified herein, may result in hazardous radiation exposure.



DANGER!

To avoid potentially fatal electrical shock hazards from electrical equipment, follow all applicable electrical codes such as (in the U.S.) the National Electrical Code.

2.3 Compliance to Standards Relevant to CE Mark

C-20 and C-30 lasers are OEM products, and are sold as components for integration into complete laser systems by a system integrator. These products are tested and CE Marked as independent products. For specific details regarding what applicable compliance directives and standards the products have been tested to, please refer to the Declaration of Conformity which is available upon request from Coherent, per contact information on p. ii of this manual.

Compliance to applicable standards for a particular laser tool incorporating C-20 and C-30 lasers must be demonstrated by the manufacturer of the complete system. The primary issue for the system integrator is to design covers, shielding, grounding, routing of electrical cable assemblies, and control elements with the proper safety features so that during subsequent testing the system meets the appropriate standards.

Coherent recommends the following guidelines to control the amount of radiated interference:

- Use high quality cables and connectors for all electrical connections
- Verify grounding of cable shields, generally at both ends of the cable

2.4 Environmental Compliance

This section describes compliance with various environmental regulator directives to identify hazardous substances.

2.4.1 Electromagnetic Compatibility

Compliance of this laser with the Electromagnetic Compatibility (EMC) requirements is certified by the CE mark. For more information about the CE mark see “Compliance to Standards Relevant to CE Mark” (p. 15).

2.4.2 RoHS Compliance

The RoHS directive restricts the use of certain hazardous substances in electrical and electronic equipment. Coherent can provide RoHS certification upon request for products requiring adherence to the RoHS Directive.

2.4.3 China RoHS Compliance

Coherent products supplied by Coherent are in conformity with applicable requirements of China's “Management Methods”, commonly referred to as China RoHS, and associated standards and applies to the production, sale, and import of products in the People's Republic of China.

The China RoHS Regulation requires that the Environment-Friendly Use Period (EFUP) symbol be displayed on any product. This symbol indicates an environment-friendly use period with the number of years inside the circle (Figure 2-2).



Figure 2-2. Environment-Friendly Use Period Symbol

2.4.5 Waste Electrical and Electronic Equipment (WEEE)

The European Waste Electrical and Electronic Equipment (WEEE) Directive (2012/19/EU) is represented by a crossed-out waste material container label. The purpose of this directive is to minimize the disposal of WEEE as unsorted municipal waste and to facilitate its separate collection.

The WEEE Directive applies to this product and any peripherals marked with this symbol. Do not dispose of these products as unsorted municipal waste. Contract the local distributor for procedures for recycling this equipment.





Figure 2-4. Waste Electrical and Electronic Equipment Label


2.5 Labeling

Refer to Figure 2-5 for a description and location of all required safety labels. These include warning labels indicating removable or displaceable protective housings, apertures through which laser radiation is emitted, and labels of certification and identification [21 CFR § 1040.10(g), 21 CFR § 1010.2, and 21 CFR § 1010.3/ EN 60825-1/IEC 60825-1, Clause 7].




Top View

Figure 2-5. Location of Safety Labels (Sheet 1 of 4)




Side Views



Front View

Back View

Figure 2-5. Location of Safety Labels (Sheet 2 of 4)



Bottom View

THIS PRODUCT IS INTENDED FOR USE SOLELY AS A COMPONENT OF AN OEM PRODUCT AND DOES NOT COMPLY WITH CDRH PERFORMANCE STANDARDS, 21 CFR SUBCHAPTER J, IF OPERATED AS A STAND-ALONE INSTRUMENT.

MODEL: XXXXXX XXXXXX XXXXXX
 XXXXXX XXXXXX

SERIAL: XXXXXXXX

PART: XXXXXXXX REV: XX

MFD / 生产日期 20XX-XX-XX
 YYYY-MM-DD

PATENT: www.coherent.com/patent

 **COHERENT**,
 1280 BLUE HILLS AVE, BLOOMFIELD, CT 06002

MADE IN USA


1. Identification Label

INVISIBLE LASER RADIATION

AVOID EYE OR SKIN EXPOSURE TO DIRECT OR SCATTERED RADIATION
 CLASS 4 LASER PRODUCT
 60 WATTS MAX AVG
 9-11um

IEC 60825-1: 2014 & EN 60825-1: 2014

1349049 Rev. 2



2. Danger of Laser Radiation Label

**WARRANTY
 VOID
 IF SEAL
 IS BROKEN**

3. Tamper Proof Label

Figure 2-5. Location of Safety Labels (Sheet 3 of 4)



4. Voltage Warning Label



5. Warning Aperture Label



6. Coolant Supply Label



7. Coolant Return Label



8. Coolant Warning

Figure 2-5. Location of Safety Labels (Sheet 4 of 4)

2.6 Sources of Additional Information

The following are sources for additional information on laser safety standards and safety equipment and training.

2.6.1 Laser Safety Standard

American National Standard for Safe Use of Lasers

ANSI Z136 Series

American National Standards Institute (ANSI)

www.ansi.org

Performance standards for light-emitting products

21 CFR Title 21 Chapter 1, Subchapter J, Part 1040

U.S. Food and Drug Administration

www.fda.gov

2.6.2 Publications and Guidelines

International Electrotechnical Commission (IEC)

www.iec.ch

A Guide for Control of Laser Hazards

American Conference of Governmental
and Industrial Hygienists (ACGIH)

www.acgih.org

Laser Safety Guide

Laser Institute of America

www.lia.org

3 DESCRIPTION AND SPECIFICATIONS

3.1 Introduction

In this section, specifications and characteristics of the C-20 and C-30 lasers will be discussed. Characteristics to be discussed include mechanical, thermal, electrical, and optical interfaces; and environmental requirements, and limitations.

C-20 and C-30 lasers are sealed-off, RF-excited CO₂ lasers, capable of continuous wave (CW) or modulated operation. From the laser safety point of view, these lasers are considered to be components and must be integrated into a system by a qualified original equipment manufacturer (OEM) prior to delivery to the end user. See “Laser Safety” (p. 9) for a complete discussion of laser safety issues.

3.2 Purpose of This Manual

This manual is designed to assist the original equipment manufacturer (OEM) during the integration of the C-20 and C-30 OEM lasers. It contains information on installation.



Figure 3-1. C-20 and C-30 Liquid-Cooled Laser

3.3 Specifications and Input Requirements

Table 3-2 (p. 28) provides specifications, configurations, and facility requirements for the C-20 and C-30 lasers. Refer to the data sheet for cooling water and power inputs specifications and requirements.

Figure 3-1 illustrates the baseline configurations (i.e., without any optional hardware additions or deletions) of the C-20 and C-30 lasers. Each laser system consists of a laser head assembly and an integrated radio frequency (RF) power supply. The RF power module converts 48 VDC, ≤ 12 A (35 A peak for 1 ms) power to radio frequency power.

Connection of the customer-supplied DC power supply to the C-20 and C-30 is via a barrier strip with screw terminals on the RF power module. These terminals should also be used for the connection of wires for remote voltage sensing. Such sensing is recommended to control the voltage at the input to the RF power module more precisely.

3.4 Hardware Overview

The C-20 and C-30 lasers are waveguide, carbon dioxide (CO₂) lasers. RF electric fields provided by the RF power module excite the CO₂ gas mixture. The standard configurations of this laser operate at wavelengths between 9 μ m and 11 μ m in the infrared region of the electromagnetic spectrum.

3.4.1 DC Input Power

DC input power is provided by the user through customer-supplied bus wiring, which goes to the RF power module. The RF power module converts this DC electrical power into RF power, which is used to excite the gas in the laser head. The DC power supply requirements are discussed in detail in the subsection entitled “DC Power Supply Requirements” (p. 41).

3.5 Cooling Requirements

Total heat dissipation for the laser is specified in Table 3-2. The laser head typically dissipates 325 W from its base surface while the RF power module typically dissipates 175 W for a total typical heat dissipation of 500 W (maximum total heat dissipation is < 575 W). The C-20 and C-30 must be provided adequate cooling to keep the laser’s operating temperature within acceptable limits. The cooling method that is used must not induce stresses that will result in misalignment of the laser resonator. The C-20 and C-30 heat sinks are designed so that the assembled structure remains free of excessive stress.

3.5.1 Comparison of Liquid Cooling & Air Cooling (Reference)

Liquid cooling and air cooling each have distinct advantages. Table 3-1 describes the factors to be taken into consideration when choosing a cooling system for a laser module.

Consideration should also be taken if condensable vapors are present and to take suitable measures to purge sensitive areas, such as optical surfaces, with a suitable gas.

Table 3-1. Comparison: The Benefits of Liquid Cooling vs. Air Cooling Methods

LIQUID COOLING	AIR COOLING
<ul style="list-style-type: none"> • Offers the highest process stability • Can yield the most compact arrangement • Suitable for applications in which the ambient air temperature exceeds 40°C • Better for applications in which the ambient air is laden with particulates • Easier to make a hermetically sealed system 	<ul style="list-style-type: none"> • Low in cost • Low in complexity • Low service requirements • Easier to install

3.5.2 Liquid-Cooling Option of C-20 and C-30

Installation requirements related to the liquid-cooling option of the C-20 and C-30 lasers are discussed in detail in “Liquid Cooling” (p. 34). This section is a quick overview only. Figure 3-2 shows the recommended connection from the customer-supplied refrigerated recirculator to the C-20 and C-30 laser systems.

Coherent recommends that the coolant water flowing from the customer-supplied refrigerated recirculator flow to the laser head, then to the RF power module. Although not shown in Figure 3-2, a flow interlock device must be provided by the customer in the cooling-water-return line to detect the presence of cooling water with the required flow rate, and to shut down the laser if adequate coolant flow is not present.




Figure 3-2. Cooling System Diagram



NOTICE!

To avoid damage to the laser, never operate the laser without a supply of cooling water meeting the requirements indicated in Table 3-2.

3.6 Laser Head

The laser head takes RF input power and converts some of it to laser radiation. The rest of the RF input power is exhausted as waste heat. For the C-20 and C-30 liquid-cooled lasers, this waste heat is exhausted into the liquid cooling water which flows through the laser head. The laser head consists of the folded optical waveguide resonator, the all-metal gas envelope structure, and RF power module. Infrared laser radiation is emitted from the optical aperture. Pictures and dimensional drawings for the C-20 and C-30 liquid-cooled lasers are shown in Figure 3-1 on page 3-23 and Figure 4-2 on page 4-33.

3.7 RF Power Module

The C-20 and C-30 RF power module converts DC input power to RF energy, which is sent to the laser head. Heat from the RF power module is exhausted into the liquid cooling water. An RJ-45-type connector is used to control the laser system. All of the user interfaces (DC power, cooling water, and signal interface) are on one panel of the RF power module.

3.8 Specifications, Configuration, and Facility Requirements

Table 3-2 describes the configuration and facility requirements for C-20 and C-30 lasers. Laser performance specifications are provided in the C-20 and C-30 Liquid-Cooled lasers data sheet available online at www.coherent.com and in the test report provided with each laser.

Table 3-2. C-20 and C-30 Liquid-Cooled Configuration and Facility Requirements

PARAMETER	VALUE
Weight	6.2 kg (13.6 lbs.)
Dimensions (LxWxH)	393 x 92.5 x 104.1 mm (15.48 x 3.64 x 4.1 in.) ¹
Input Power	48 VDC ± 2% regulation, < ± 1% P-P Noise/Ripple 11.5 A, and 18 A peak for 1 ms minimum, measured at input terminals
Cooling	Liquid
Heat Dissipation (W)	< 575 W
Maximum Case Temperature	< 60°C (140°F)
Operating Environment	
Temperature	5 to 40°C (41 to 104°F)
Altitude	< 2,000 m (6,500 ft.)
Humidity	Non-condensing
Shipping/Storage Environment	- 10 to 60°C (14 to 140°F), non-condensing
Coolant	Distilled water with 25 to 35% Dow Frost*
Coolant Flow Rate	> 3.8 lpm (1.0 gpm)
Maximum Coolant Pressure	6.9 bar (100 psig)
Coolant Temperature	15 to 30°C (59 to 86°F)
¹ Optional fans add 1 A. ² The overall height dimension is taller for the Dual Chillplate version of this item. *Dow Frost is a trademark of the Dow Chemical Company.	

4 UTILITY REQUIREMENTS AND SYSTEM INSTALLATION

4.1 Introduction

This section covers unpacking and installation of the C-20 and C-30 lasers. Detailed operating instructions are given in “Laser Operation” (p. 41) in the operator’s manual.

4.2 Unpacking and Inspection

Before unpacking the laser components, inspect the shipping carton for evidence of rough handling, and note any damage. If damage to the shipping carton is evident, request the carrier’s agent be present when the unit is unpacked. Inform the shipping carrier and Coherent of any evidence of damage in shipment. The buyer and shipping carrier is responsible for any damage which occurs during shipment.

4.2.1 Verifying Delivery

The shipping container contains the following:

- Laser head and integral RF power module
- Final test sheet

If any of these items are missing, report this to Coherent immediately.

4.2.2 Protective Shipping Tape

The front of the C-20 and C-30 laser head is protected by a blue adhesive film or tape (see Figure 4-1 on page 30). This tape is designed to protect the optics during shipping and must be removed prior to operating the laser.



NOTICE

To avoid damage, the blue protective tape must be removed **BEFORE** operating the laser.




Figure 4-1. Protective Shipping Tape

4.2.2.1

Tape Removal

To remove the protective tape:

1. Pinch one corner of the tape between the thumb and index fingers.
2. Gently pull the tape off of the laser.

Discard the tape and do not place the tape anywhere near or on the laser.

4.3

Safety Issues in Laser Installation

Installation of the C-20 and C-30 lasers must comply with all applicable electrical safety and laser safety laws and regulations. Review “Laser Safety” (p. 9) for important information relating to safety.

The negative (return) side of the DC input connection to the C-20 and C-30 RF power module is connected internally to the chassis. The user must assure that the system into which the C-20 and C-30 is built protects against the possibility that the laser head or RF power module chassis could be at a hazardous voltage and that personnel could be exposed to these voltages.



DANGER!

To avoid potentially fatal electrical shock hazards from electrical equipment, follow all applicable electrical codes such as (in the U.S.) the National Electrical Code.

The laser must be secured properly to avoid the possibility of the laser shifting unexpectedly during operation, creating a hazardous condition. The location of the output beam of the C-20 and C-30 laser head is shown in Figure 4-2. The laser output is emitted from the aperture shown in the referenced figure and propagates within a full cone angle up to 5°. The acceptance angle of the system aperture must intercept all of the output of the laser.

It is also extremely important to understand the direction, divergence, and magnitude of all reflections that will occur from optical surfaces. Infrared (IR) beams, such as those from the C-20 and C-30 lasers, can also be located with commercially available IR screens, such as those produced by Macken Instruments, Inc. [tel. (707) 566-2110]. Coherent recommends that all beam propagation paths be enclosed and that personnel operating the laser be qualified optical technicians who are familiar with this type of hardware.

4.4 Mechanical Mounting

The dimensions for the C-20 and C-30 laser heads are shown in Figure 4-2. Mechanical mounting of the C-20 and C-30 laser head must result in no distortion or stress the laser head in any way. Otherwise, optical alignment and power stability could be adversely affected.

4.4.1 Mounting Considerations for C-20 and C-30

Certain aspects of specific customer applications may preclude absolute interchangeability of laser heads. For example, for certain applications, the sensitivity of the application to optical beam pointing errors may require external optical realignment after the laser head is replaced in the customer's integrated system. Depending on the method of mounting and the sensitivity of the integrated customer system to beam pointing errors, even removing a laser head from the customer's system, then replacing the same laser head back into the customer's system may require external optical realignment. This external alignment would be a repositioning of the head itself or adjustment of beam delivery mirrors (positions and angle). Consult Coherent if there is any question about such interchangeability issues.

Coherent recommends use of the optional brackets (part number 1101-12-0016 for a set of 4) that are designed for mounting the laser safely without inducing any stress onto the laser. Care must be taken not to induce stress onto the laser head, as optical mis-alignment of the laser resonator can occur, which would require the laser to be returned to Coherent for service. A mechanical drawing for this bracket is provided in the Appendix A. Coherent strongly encourages use of this bracket or a similar design in order to accommodate temperature changes in operation while providing secure mounting.




Figure 4-2. C-20 and C-30 Liquid-Cooled Laser Head Dimensions

4.5 Liquid Cooling

The C-20 and C-30 liquid-cooled lasers are cooled by means of liquid coolant. The cooling system, external to the laser head and the RF power module, is the responsibility of and must be supplied by the user. A schematic of the recommended configuration of the cooling system is shown in Figure 4-3.




Figure 4-3. Recommended Liquid Cooling System Functional Block Diagram

4.5.1 Cooling System Layout

By connecting the laser head and the RF power module in series, a single interlock will protect the laser system.

Following the flow of coolant from the refrigerated recirculator, the laser head is the first element reached by the coolant after it leaves the recirculator. This assures that the laser head receives the lowest-temperature coolant available.

To prevent inadvertent operation of the laser without adequate coolant, an interlock must be provided so that laser operation is halted. Refer to coolant requirements in Table 3-2 (p. 28).

4.5.2 Coolant Composition

The required coolant composition is a mixture of clean distilled water containing a low toxicity corrosion inhibitor. THE USE OF CORROSION INHIBITOR IS MANDATORY IN THE C-20 AND C-30 LASERS! Coherent has tested three different solutions that will prevent corrosion within the laser coolant circuit.

These are described in Table:

Table 4-1. Recommended Coolant for C-20 and C-30 Lasers

PRODUCT NAME	MANUFACTURERS NAME AND CONTACT	HEAT TRANSFER FLUID TYPE	REQUIRED HEAT TRANSFER FLUID CONTENT	FREEZING BURST PROTECTION	OTHER PRECAUTIONS
Optishield	OptiTemp. Inc. www.optitempt.com US/Canada 231-946-2931	Corrosion Inhibited Water	10% solution in water	Does not reduce the water freezing point	Use may be restricted in geographical locations outside the US
WT1000	Nalco Inc. www.nalco.com US 630-305-1000	Corrosion Inhibited Water	2500 ppm in water (2.5 mL per liter of water)	Does not reduce the water freezing point	Use may be restricted in geographical locations outside the US
Dowfrost	Dow Chemical Inc. www.dow.com 989-636-1000	Inhibited Propylene Glycol and Water	30% in water	At 30% mix will provide burst protection to --25°C (13°F)	See Note below

Note on the use of Dowfrost:



Using Dowfrost at 30% in distilled water changes the heat transfer capacity of the water and also its viscosity. This means that the laser will be efficiently cooled as long as the specified flowrate of 1 gpm is maintained.



NOTICE!

Failure to provide adequate cooling to the laser will result in unstable operation and potential failure.

Figure 4-4 shows system components from water circuits treated with inhibitor and a water circuit without inhibitor.



Figure 4-4. Water Circuits - Untreated and Treated

4.5.3

Re-Circulation and Coolant Flow Interlock Switch

The coolant flow interlock switch should be the last element traversed by the coolant before it returns to the coolant filter in the return line. This assures that the flow switch verifies that coolant is flowing through the laser system. The flow switch must not be placed in any other position. The interlock, which is tripped when the coolant switch indicates no flow or low flow, cuts off AC power to the RF power module to prevent the system from overheating.

4.5.4

Signal Interface

The signal interface in the laser interlock system may be used to turn the laser off when the coolant interlock is breached. With this approach, the laser is commanded to shut down via the signal interface, in the event that the coolant interlock system detects a coolant fault. Coherent recommends that both Modulation and Control Enable be commanded to the OFF state when the coolant interlock system detects a coolant fault. These signals are listed in Table 4-2, "Signal Interface Description and Connector Pinout," on page 43 and described in subsections of "Laser Operation".

4.5.5 Thermal Shutdown Circuit

The C-20 and C-30 lasers have a thermal protection circuit that protects the system at case temperatures over 80°C. Coherent recommends, however, that the OEM install sensors that detect coolant flow and shuts the laser down in the event of loss of coolant.

The system also provides a high temperature warning. This warning is used to alert the user to the need of maintenance in order to return the cooling system performance back to normal, full cooling capacity. Failure to take action regarding the temperature warning will result in poorer product performance (outside specifications) and lesser product life time.

4.5.6 DC Power Relay

The recommended DC power relay used to cut DC power to the laser off, in the event of cooling system failure, can also be used as part of the laser safety interlock system. Similarly, if the signal interface is used to shut down the laser when there is a cooling system fault, the signal interface can be used to shut down the laser in the event that there is a breach of a safety interlock. The design of the interlock controls must be in compliance with applicable safety standards, including those described in “Laser Safety” (p. 9).

4.5.7 Condensation of Water Vapor

If the coolant temperature is below the dew point of the ambient air, water will condense out of the air onto the outside of the laser head. It will also form onto the outside surface and internal surfaces of the RF power module. Condensation can damage the output optical element of the laser head when the laser is turned on, and could damage internal components of the RF power module if power is applied while condensate is present.



NOTICE!

To avoid damage to the laser head and RF power module, never allow the coolant temperature to fall below the dew point of the ambient air. Turn the coolant flow off if the laser will be off or stored for an extended period of time in humid conditions.

If necessary, the laser system can operate with coolant temperatures slightly below the dew point of the ambient air. This requires special procedures to be followed, such as shutting off the coolant flow at all times when the laser is not producing laser output. Contact Coherent Customer Service for more information about this option before attempting to operate the system in ambient air below the dew point.



NOTICE!

To avoid possible damage to the laser head, never attempt to change the coolant fittings at the locations where the coolant enters the laser head. If the fittings must be changed for any reason, return the laser head to Coherent to be serviced by Coherent technicians.

4.5.8 Coolant Fittings on Laser System

The C-20 and C-30 liquid cooled lasers have 6 mm O.D. tubing for the connection interface. The user must supply an appropriate compression fitting to make the connection with the rest of the user's system.




Figure 4-5. C-20 and C-30 Liquid Cooling Connections

4.5.9 Cooling Capacity

The cooling system must have sufficient capacity to maintain the coolant temperature at the outlet of the refrigerated recirculator within the range given in Table 3-2 (p. 28). With the laser operating at its maximum output power, the cooling system must dissipate up to 575 W. See “Maintenance and Troubleshooting” for maintenance and replacement requirements for the coolant.

4.5.10 Coolant Filtering

Coherent recommends that the user incorporate coolant filtering in the coolant return line to avoid the accumulation of debris in the cooling system, as shown in Figure 4-3. The filter should trap particles larger than 30 μm to 50 μm in size, unless specified otherwise by the manufacturer of the refrigerated recirculator.

4.5.11 Coolant Flow Rate and Pressure

Requirements on coolant flow rate are listed in Table 3-2 (p. 28). To prevent damage to the laser head or the RF power module, the gauge pressure of the coolant at the laser head and at the RF power module must not exceed 100 psig (i.e. the gauge pressure - the difference between the absolute pressure of the coolant and the absolute pressure of the ambient air - must not exceed $7\text{kg}/\text{cm}^2$, or 690 kPa). Note that the gauge pressure at the laser system includes the effect of the gravitational pressure change if the refrigerated recirculator is mounted much higher than the laser system.



NOTICE!

Exceeding the maximum allowed gauge pressure in the laser head or RF power module, even for a short period of time, may cause irreversible damage and result in permanent coolant leaks.

Depending on the customer's overall cooling system design, portions of the cooling system other than the laser head and the RF power module, may limit the maximum-allowed gauge pressure of the coolant to a lower pressure than the value noted above for the laser head and the RF power module.

4.5.12 Pressure Drop


The pressure drop from the coolant outlet to the coolant inlet of the refrigerated recirculator will depend on many factors, including:

- Flow rate
- Temperature
- Length and inside diameter of coolant hoses and connections
- Coolant composition

To achieve the minimum flow rates given in Table 3-2 (p. 28), provide a pressure drop of no more than 22 psi ($1.55\text{ kg}/\text{cm}^2$) between coolant inlet and coolant outlet of the laser. In addition, there is some pressure drop in the cooling lines, which depends primarily on the diameter and length of these lines.

4.6 Electrical Power Connection

The C-20 and C-30 lasers require 48 VDC input DC power. This power is carried from the power source to the system through the terminal block on the C-20 and C-30. The maximum current required is 11.5 A, and 18 A peak for 1 ms minimum, measured at input terminals.



Note: Pin #1 of RJ45 control interface is on the left as viewed.

Figure 4-6. Electrical Connections to C-20 and C-30



NOTICE!

To avoid damage to the head, connect leads to the user-supplied power source last after other connection are made.

The negative (return) side of the DC input connection to the C-20 and C-30 RF power module is connected internally to the chassis. The user must assure that the system into which the C-20 and C-30 is built protects against the possibility that the C-20 and C-30 chassis could be at a hazardous voltage and that personnel could be exposed to these voltages.



DANGER!

To avoid potentially fatal electrical shock hazards from electrical equipment, follow all applicable electrical codes such as (in the U.S.) the National Electrical Code.

Coherent strongly recommends that the user review the precautions described in “Laser Safety” (p. 9) regarding electrical safety before using the C-20 and C-30 lasers. It is the user’s responsibility to provide circuit breakers and/or fusing of the AC power source in accordance with all applicable laws and regulations.

4.6.1

DC Power Supply Requirements

The following are the requirements for the customer-supplied DC power supplies.

DC Voltage:	48 VDC measured at the terminals.
Peak Current:	18 A for a minimum of 1 ms with a maximum voltage drop of 1.5 V
Regulation:	< $\pm 2\%$
Regulation Sensing:	Remote at load
Ripple and Noise:	< 1% p-p (20 MHz BW limit)
Overload and Short Circuit Protect:	Automatic Recovery

4.6.1.1

DC Power Supply Cabling Requirements



Coherent recommends the use of remote voltage sense/regulation at the C-20 and C-30. This requires a 4-wire cable (2 supply currents and 2 voltage senses).

The following requirement minimizes the voltage loss from supply to the C-20 and C-30:

WIRE LENGTH (IN METERS)	AWG
0-2	18
2-3	16
3-5	14
5-8	12
8-12	10
12-20	8

4.7 Control Signal Connection

Electrical control of the C-20 and C-30 lasers is achieved via an RJ-45 connector built into the system. The signals carried on each of the pins are indicated in Table 4-2. Details about controlling the laser through the signal interface are discussed in “Laser Operation” in the operator’s manual.



NOTICE!

Coherent highly recommends use of shielded interface cables. The interface cable shield must connect to the chassis ground of the controller. In addition to proper shielding, this shield provides a secondary connection for the signal ground (Pin 8).

A floating ground connection (use of un-shielded interface cable or no return path between the host control electronics and the laser) can present an unsafe condition and result in unstable or unexpected operation of the laser. This condition can arise when the control signal ground connection (Pin 8) is lost and the Control Enable (Pin 7) and Modulation (Pin 1) remain high. Therefore, Coherent strongly recommends that a second safety ground be provided either via a shielded control cable or common potential chassis mounting between the laser head and the control electronics. Inadequate or nonexistent grounding between the laser and the external control system can result in loss of control of the laser and damage to the laser electronics or the external control electronics.

Table 4-2. Signal Interface Description and Connector Pinout

PIN NO.	SIGNAL DESCRIPTION
1	Modulation TTL logic input; 1=RF ON, 0=RF OFF; 1 k Ω impedance This input turns on the laser. See also Pin 7, Control Enable, below
2	+ 15 VDC \pm 0.5 VDC, 0.25 Amps Max output for customer use
3	LASER OK TTL logic output; 1=LASER OK, 0=LASER Fault; I _{OH} = -0.4 mA, I _{OL} = 8 mA Output is asserted when no faults (VSWR, Temp. or Volt.) are detected The temperature fault will occur at a case temperature of approximately 80°C
4	Temperature OK TTL logic output; 1=Temp OK, 0=Temp Fault; I _{OH} = -0.4 mA, I _{OL} = 8 mA Output is asserted when temperature is below the 60°C case temperature warning level
5	Voltage OK TTL logic output; 1=Voltage OK, 0=Voltage Fault; I _{OH} = -0.4 mA, I _{OL} = 8 mA Output is asserted when DC supply voltage (V _{DD}) is between 43 VDC < V _{DD} < 55VDC
6	Internal Coherent use; must be grounded or not connected by OEM
7	Control Enable TTL logic input; 1=Laser Control Enabled, 0=Laser Control Disabled This input must be asserted before Modulation can be used to turn on laser
8	Customer Logic Ground for all interface signals
Notes: 1) Connector used is RJ-45 type. 2) These specifications are subject to change.	

4.8 Beam Propagation

The true waveguide structure of the C-20 and C-30 delivers a 1.8 mm $1/e^2$ diameter beam with a 7.5 mrad $1/e^2$ full angle divergence. The typical beam diameter as a function of distance from the laser is shown in Figure 4-7.





Figure 4-7. Beam Diameter vs. Distance from Laser Head



DIAMOND C-20 and C-30 Liquid-Cooled OEM Lasers Preinstallation Manual
©Coherent Inc., 2/2020 (RoHS), printed in the USA and Thailand
Part No. 1424909 Rev. AF

